


College of Pharmacists of British Columbia



PHARMACY LICENSURE

DIAGRAM REQUIREMENTS (COMMUNITY PHARMACY/TELEPHARMACY)

The following items must be shown on the pharmacy diagram:

- The diagram is professionally drawn to scale (recommended: ¼ inch = 1 foot).
- The diagram includes the scale and measurements.
- The diagram labels each item listed below (as applicable).

PHARMACY (EXTERNAL TO DISPENSARY)

- Entrance(s) to the pharmacy/premises
- Professional Products Area (for Schedule 3 drugs) – max 25 feet from the perimeter of the dispensary
OR N/A – no public access or Other reason: _____
- Location of “Medication Information” sign
OR N/A – Pharmacy comprises 100% of the total area of the premises
- Separate injection room for injectable opioid agonist treatment (iOAT) including:
 - Stainless steel table AND Sink
 - OR** N/A – Pharmacy does not provide iOAT services

DISPENSARY

- Entrance(s) to the dispensary by means of (*select all that apply*):
 - Gate Lift-up countertop with gate Full-door Dutch-door Other – Specify method used to make the dispensary inaccessible to the public: _____
- Physical barriers securing Schedule 1 and 2 drugs, controlled drug substances, and personal health information
OR N/A – Premises is not accessible to non-registrants when no full pharmacist is present
- Dispensary area – minimum 160 square feet (highlight perimeter of dispensary)
- Professional Service Area (for Schedule 2 drugs)
- Service counter(s) for prescriptions pick-up and drop-off
- Consultation area:
 - Private consultation room Semi-private area with suitable barriers
- Dispensing counter(s) of *clear* working space – minimum 30 square feet in total (highlight perimeter of working space)
- Computer terminal(s) on dispensing counter(s) – 1 computer terminal ≈ 4 square feet of working space which is not included in the total dispensing counter space
- Shelving
- Double stainless steel sink
- Metal safe with a time delay lock **OR** Safe Declaration (Appendix 1 from [PPP-74](#))
- Refrigerator

College of Pharmacists of British Columbia



PHARMACY LICENSURE

DIAGRAM REQUIREMENTS (COMMUNITY PHARMACY/TELEPHARMACY)

IF APPLICABLE: STERILE COMPOUNDING (NON-HAZARDOUS and/or HAZARDOUS)

The following items must be shown on the pharmacy diagram:

- Relative air pressure (positive or negative) of each room
- ISO class (for each room and any PEC inside of the room)

Sterile Compounding Areas:

- Anteroom (*select all the apply*): Non-Hazardous Hazardous Shared
- Clean room (*select all the apply*): Non-Hazardous Hazardous
- Segregated area (*select all the apply*): Non-Hazardous Hazardous N/A
- Pass-through **OR** N/A
- Demarcation line(s)
- Storage area for hazardous products **OR** N/A
- Storage area for cleaning equipment and supplies

Equipment:

- Hands-free sink (in each anteroom)
- Eyewash station
- Refrigerator (select location below) **OR** N/A
 - Location(s): Anteroom Clean room Dedicated storage area (hazardous drugs)
- Freezer (select location below) **OR** N/A
 - Location(s): Anteroom Clean room Dedicated storage area (hazardous drugs)
- Primary Engineering Control (PEC) (*select all the apply*):
 - Non-Hazardous clean room: LAFW CAI N/A
 - Non-Hazardous segregated area: LAFW CAI N/A
 - Hazardous clean room: Class II or III BSC CACI N/A
 - Hazardous segregated area: Class II or III BSC CACI N/A